

CRAWFORD MESA WATER ASSOCIATION
SPECIFICATIONS
FOR NEW METER INSTALLATIONS

Member is responsible for all expenses in the location of the water line for the installation of a new water meter; trenching, pipe, permits, tracer line and incidental expenses.

CMWA will specify the size and class of the pipe to be installed and will designate the location for the meter. CMWA will pay for the first 150 feet of pipe, the meter pit and the meter. The meter will be installed where the property transitions to private property. The manager will install the meter and tap into the main line. The manager must be present to assist in locating the line.

If pipe must be installed, an 18" wide minimum trench shall be required and a minimum of 42" cover over the top of the pipe. There will be a minimum of 4" bedding below the pipe in rocky areas. The top of the pipe shall be hand bedded at least 4" before backfill. CMWA may specify more bedding in rocky soils.

There will be at least a minimum of 60" depth cover for the traveled portion of any road, from borrow ditch to borrow ditch. The pipeline will be encased in a Schedule 80 plastic pipe. The Schedule 80 will be at least two inches larger than the pipeline being installed and the pipeline will have glued joints.

The manager and two board members shall inspect and approve the trench before the pipe is covered. After the pipe is installed and bedded, the manager and two board members shall inspect and approve the pipe as bedded before backfill and photographs shall be taken.

No gas, electrical or telephone lines shall be installed in the same trench with the pipeline. The applicant will be billed for the cost of tracer line.

Member hereby agrees to the above specifications.

Name (Please print)

Signature

Address

Date